

Project:

Order No: Premio EPS80 Compression test

Part No: Premio EPS80/2021_05_18


Customer: Premio Hungária

Tester: Thümler GmbH-Z5

Method: MSZ EN 826

Execution date: 2021. 05. 18. 11:51:09

Chart:



Results:

Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
Premio EPS80/2021_05 _18(1)	86,50	9,99
Premio EPS80/2021_05 _18(2)	86,36	10,00
Premio EPS80/2021_05 _18(3)	86,09	9,99
Premio EPS80/2021_05 _18(4)	85,63	9,99
Max.	86,50	10,00
Min.	85,63	9,99
Mean	86,15	9,99