


Project:

Order No: Premio EPS100 Compression test
Part No: Premio EPS100/2022_10_10
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2022. 10. 10. 8:43:28

Chart:



Results:

Nom	Stress [kPa] ,max.	
Premio EPS100/2022_1 0_10(1)	107,70	
Premio EPS100/2022_1 0_10(2)	112,87	
Premio EPS100/2022_1 0_10(3)	106,00	
Max.	112,87	0
Mean	108,86	0