


Project:

Order No: Premio EPS100 Compression test
Part No: Premio EPS100_2023_10_23
Customer: Premio Hungária

Tester: Thümler GmbH-Z5
Method: MSZ EN 826
Execution date: 2023.10.23.

Chart:



Results:	Nom	Stress [kPa] ,max.	Displacement [mm] ,max.
	Premio EPS 100_2023_10_23	104,10	10,00
	Premio EPS 100_2023_10_23	99,84	9,99
	Premio EPS 100_2023_10_23	102,62	9,99
	Premio EPS 100_2023_10_23	101,46	9,99
	Premio EPS 100_2023_10_23	101,05	10,00
	Mean	101,81	9,99